


Prestige EnviroMicrobiology, Inc.



Analytical Test Report

Client: Garden State Environmental, 555 South Broad Street, Suite K, Glen Rock, NJ 07452

Client Project/Name: Kelly Elementary

Sample date: 8-29-2018

Submittal date: 8-31-2018

Samples submitted by: TE


Date analysis completed: September 11, 2018; amended September 18, 2018

Prestige report number: 180831-10A

Culture Method (P031): Analysis of Water Samples for *Legionella* bacteria

Prestige # Client sample ID Location	<i>Legionella</i> Identification	Conc. (CFU/mL)	Percentage
180831-10-119 KES-B-S-09 Boiler Room	Not detected	ND	NA
180831-10-120 KES-B-HWH-01 Boiler Room	Not detected	ND	NA
180831-10-121 KES-B-S-01 Boys RR next to 208 (Middle)	Not detected	ND	NA
180831-10-122 KES-1-S-02 Boys RR Across from Library (Left)	Not detected	ND	NA
180831-10-123 KES-1-S-03 Nurse	Not detected	ND	NA
180831-10-124 KES-1-S-04 Girls RR by Grade 1 (Left)	Not detected	ND	NA
180831-10-125 KES-1-S-05 Room 102	Not detected	ND	NA
180831-10-126 KES-2-S-06 Boys RR (Left)	Not detected	ND	NA
180831-10-127 KES-2-S-07 Room 207	Not detected	ND	NA
180831-10-128 KES-2-S-08 Room 201	Not detected	ND	NA

Prestige EnviroMicrobiology, Inc.



Report approved: Theresa Lehman
Theresa Lehman, MPH, Lab Director

Technical Manager: Chin S Yang
Chin S Yang, Ph.D.

Analyst: Theresa Lehman, MPH / Ching-Yi Tsai, Ph.D.

1. The samples in this report were received in good, acceptable conditions. Prestige EnviroMicrobiology has not performed sample collection for the sample items listed in this report. Results relate only to the items tested.
2. Percentage is for each species or serotype of *Legionella* in total population.
3. Concentrations and percentages are rounded to the nearest two significant digits. Total percentage may not add up to 100% due to rounding.
4. Sample analysis is based on the "Procedures for the Recovery of *Legionella* from the Environment" published by the Centers for Disease Control and Prevention in 2005.
5. SG = Serogroup; NA = not applicable; ND = not detected.
6. For technical information on result interpretation, please visit www.Prestige-EM.com.
7. Report amended to recalculate concentrations in "CFU/mL" from "CFU/L".