


Prestige EnviroMicrobiology, Inc.



Analytical Test Report

Client: Garden State Environmental, 555 South Broad Street, Suite K, Glen Rock, NJ 07452

Client Project/Name: Early Education Center

Sample date: 8-30-2018

Submittal date: 8-31-2018

Samples submitted by: TE

Date analysis completed: September 10, 2018; amended September 18, 2018

Prestige report number: 180831-14A

Culture Method (P031): Analysis of Water Samples for *Legionella* bacteria

Prestige # Client sample ID Location	<i>Legionella</i> Identification	Conc. (CFU/mL)	Percentage
180831-14-157 EEC-1-S-01 Kitchen	Not detected	ND	NA
180831-14-158 EEC-1-S-02 Nurse	Not detected	ND	NA
180831-14-159 EEC-1-S-03 Room 2 (Left)	Not detected	ND	NA
180831-14-160 EEC-1-S-04 Room 4 (Right)	Not detected	ND	NA


Report approved: Theresa Lehman
Theresa Lehman, MPH, Lab Director

Technical Manager: Chin S Yang
Chin S Yang, Ph.D.

Analyst: Theresa Lehman, MPH / Ching-Yi Tsai, Ph.D.

1. The samples in this report were received in good, acceptable conditions. Prestige EnviroMicrobiology has not performed sample collection for the sample items listed in this report. Results relate only to the items tested.
2. Percentage is for each species or serotype of *Legionella* in total population.
3. Concentrations and percentages are rounded to the nearest two significant digits. Total percentage may not add up to 100% due to rounding.

Prestige EnviroMicrobiology, Inc.



4. Sample analysis is based on the "Procedures for the Recovery of *Legionella* from the Environment" published by the Centers for Disease Control and Prevention in 2005.
5. SG = Serogroup; NA = not applicable; ND = not detected.
6. For technical information on result interpretation, please visit www.Prestige-EM.com.
7. Report amended to recalculate concentrations in "CFU/mL" from "CFU/L".