

Project: Redwood Elementary School
New Jersey American Water Laboratory - North (# 07097)

<u>Site</u>	<u>Date Sampled</u>	<u>Time Sampled</u>	<u>Sampler</u>	<u>pH (units)</u>	<u>Temp. (Degrees C)</u>	<u>Free Chlorine (mg/L)</u>	<u>Conductivity (uS)</u>	<u>Total Coliforms/100 ml</u>
Kitchen Sink	8/30/2018	8:51	JW	8.1	25.7	0.79	324	0
Boiler Room Sink	8/30/2018	8:37	JW	7.9	24.7	0.85	323	0
Fountain - New Gym Foyer	8/30/2018	9:24	JW	8.2	22.3	1.04	312	0
Fountain - Room 305	8/30/2018	9:30	JW	8.2	26.8	0.94	326	0
Fountain - Room 503	8/30/2018	9:02	JW	8.4	19.8	1.02	323	0
Fountain - Room 606	8/30/2018	9:14	JW	8.4	19.5	1.11	322	0