


# Prestige EnviroMicrobiology, Inc.



## Analytical Test Report

Client: Omega Environmental Services, Inc., 280 Huyler Street, South Hackensack, NJ 07606

Client Project/Name: 19-1025E / West Orange School District – Edison Central School

Sample date: 5-9-2019

Submittal date: 5-9-2019

Samples submitted by: Larry Zaccherio

Date analysis completed: May 20, 2019


Prestige report number: 190510-02

### Culture Method (P031): Analysis of Water Samples for *Legionella* bacteria

Prestige # Client sample ID Location	<i>Legionella</i> Identification	Conc. (CFU/ mL)	Percentage
190510-02-012 01 Basement – Hallway by Room 8 Unit 1 of 2 CW	<i>Legionella</i> (b-m) spp.*	0.1	100%
190510-02-013 02 2 <sup>nd</sup> FL – Hallway by Copy Room CW	<i>Legionella</i> (b-m) spp.*	0.3	100%
190510-02-014 03 2 <sup>nd</sup> FL – Hallway across from Rm 210 CW	<i>Legionella</i> (b-m) spp.*	0.1	100%
190510-02-015 05 1 <sup>st</sup> – Hallway by Main Office CW	Not detected	ND	NA
190510-02-016 06 1 <sup>st</sup> – Hallway by Guidance Office Rm 110 CW	Not detected	ND	NA
190510-02-017 07 1 <sup>st</sup> – Hallway outside Gym CW	Not detected	ND	NA
190510-02-018 08 1 <sup>st</sup> – Inside Gym Girl's Side CW	Not detected	ND	NA
190510-02-019 09 1 <sup>st</sup> – Inside Gym Boy's Side CW	<i>Legionella</i> (b-m) spp.*	0.1	100%

\* The isolates were positive for *Legionella* spp., in the group including *L. jordanis*, *L. oakridgensis*, *L. wadsworthii*, *L. feeleii*, *L. sainthelensi*, *L. anisa*, *L. santicrucis*, *L. spiritensis*, *L. hackeliae*, *L. maceachernii*, *L. bozemanii*, *L. dumoffii*, *L. gormanii*, *L. micdadei*, and *L. longbeachae*.

***Prestige EnviroMicrobiology, Inc.***



Report approved: Theresa Lehman  
Theresa Lehman, MPH, Lab Director

Technical Manager: Chin S Yang  
Chin S Yang, Ph.D.

Analyst: Theresa Lehman, MPH / Ching-Yi Tsai, Ph.D.

1. The samples in this report were received in good, acceptable conditions. Prestige EnviroMicrobiology has not performed sample collection for the sample items listed in this report. Results relate only to the items tested.
2. Percentage is for each species or serotype of *Legionella* in total population.
3. Concentrations and percentages are rounded. Total percentage may not add up to 100% due to rounding.
4. Sample analysis is based on the "Procedures for the Recovery of *Legionella* from the Environment" published by the Centers for Disease Control and Prevention in 2005.
5. SG = Serogroup; NA = not applicable; ND = not detected.
6. Prestige EnviroMicrobiology, Inc., is an Approved Environmental Laboratory for *Legionella* testing by the State of Connecticut, Department of Public Health (CT Registration number: PH-0608); by the State of New York Department of Health (NY Lab ID no: 12057); and a successful participant of CDC's Environmental *Legionella* Isolation Techniques Evaluation (ELITE) program since 2009.
7. NYSDOH ELAP certification does not include serogroup identifications.
8. For technical information on result interpretation, please visit [www.Prestige-EM.com](http://www.Prestige-EM.com).